

Brim Technologies
151 Industrial Way East
Eatontown, NJ 07724

Phone: (973) 895-8826
Fax: (973) 895-2108

CERTIFICATE OF ANALYSIS

PRODUCT: Safe DChlor T30

LOT NO. : 70623

Date(s) of Mfg: 6/23/2017

Re-Test Date: 6/23/2022

Analysis	Results	Limits
Sodium Thiosulfate, mg/tablet:	32.3	30-38
Tablet Weight, (mg):	102	100 ± 10
Tablet Diameter (inch):	0.18	0.185 ± 0.01
Tablet Hardness, (Kp):	4.9	3-6

The following Lot(s) have been analyzed and comply with the limits for the parameters shown on this certificate.

EK Sullivan

6/27/2017

Edward K. Sullivan
Brim Technologies

Date